


# 品

## II型自愿认证

证书编号: CQC2002010308025024



**委托人名称及注册地址** 浙江天正电气股份有限公司  
浙江省乐清市柳市镇苏吕工业区

**制造商名称及注册地址** 浙江天正电气股份有限公司  
浙江省乐清市柳市镇苏吕工业区

**生产企业名称及生产地址** 浙江天正电气股份有限公司  
浙江省乐清市柳市镇柳乐路 332 号

**产品名称和系列、规格、型号** 刀型触头熔断器  
RT16(Z)-(A)00;详见附件

**产品标准和技术要求** GB/T 13539.2-2015

**认证模式** 产品型式试验+初次工厂检查+获证后监督

可通过扫描下方二维码或登录国家认监委网站 ( www.cnca.gov.cn ) 查验证书信息

授权签字人 签发  
陈昕 陆楠

### 中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0056307

# CERTIFICATE OF PRODUCT CERTIFICATION

## TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2002010308025024

Valid from: Aug.24,2020

Valid until: May.20,2031

**NAME AND REGISTERED ADDRESS OF THE APPLICANT** Zhejiang Tengen Electric Co.,Ltd.  
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

**NAME AND REGISTERED ADDRESS OF THE MANUFACTURER** Zhejiang Tengen Electric Co.,Ltd.  
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

**NAME AND LOCATION OF THE FACTORY** Zhejiang Tengen Electric Co.,Ltd.  
No.332 Liule Road, Liushi Town, Yueqing City, Zhejiang Province, P.R.China



**PRODUCT NAME, MODEL AND SPECIFICATION** Fuses with fuse-links with blade contacts  
RT16(Z)-(A)00;See the appendix

**THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS** GB/T 13539.2-2015

**TYPE OF CERTIFICATION SCHEMES** Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.  
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

For more information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)

**SIGN BY** **SIGNATURE**  
 

**CHINA QUALITY CERTIFICATION CENTRE**



# 产品认证证书

## II型自愿认证

附 录

证书编号: CQC2002010308025024

第 1 页 共 1 页

纸 号: 56307

RT16(Z)-(A)00;

熔断体:

Un: AC500/AC690V(RT16-00, RT16-A00),

AC500/AC690V, DC250V/DC440V (RT16Z-00, RT16Z-A00);

In: 2A, 4A, 6A, 8A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, 80A, 100A, 125A, 160A;

额定分断能力(I1): 120kA/AC500V, 50kA/AC690V, 100kA/DC250V, 50kA/DC440V;

分断范围和使用类别:gG

熔断器支持件:

Un: AC500/AC690V(RT16-00, RT16-A00), AC500/AC690V /DC440(RT16Z-00,

RT16Z-A00);

In:160A;

1P;

峰值耐受电流:120kA/AC500V, 50kA/AC690V, 100kA/DC250V, 50kA/DC440V

注: 此附录与证书同时使用时有效。



中国质量认证中心

